
## **VIBRATION MANAGEMENT CORPORATION**

5930 THOMAS ROAD, HOUSTON, TEXAS 77041, U.S.A

**INTERNET ADDRESS: www.vimco.biz** 

MODEL	SIZE	LENGTH	AXIAL	AXIAL	TRANSVERSE	ANGULAR	OPERATING	BURST	TEMP.	
		(F/F)	COMPRESSION	ELONGATION	DEFLECTION	DEFLECTION	PRESSURE	PRESSURE	RANGE	
	(inches)	(inches)	(inches)	(inches)	(inches)	(deg)	(psig)	(psig)	(°F)	
FCU-T-5	1/2	8	7/8	1/4	7/8	30°	232	725	14 - 158	
FCU-T-7	3/4	8	7/8	1/4	7/8	30°	232	725	14 - 158	
FCU-T-10	1	8	7/8	1/4	7/8	25°	232	725	14 - 158	
FCU-T-12	1 1/4	8	7/8	1/4	7/8	25°	232	725	14 - 158	
FCU-T-15	1 1/2	8	7/8	1/4	7/8	20°	232	725	14 - 158	
FCU-T-20	2	8	7/8	1/4	7/8	15°	232	725	14 - 158	
* Define indicated above and for any first and a first										





\* Ratings indicated above are for constant pressures at 100°F. For pulsating pressures use 1/2 of rating, for surge pressures use 1/6 of rating. For higher temperature applications contact factory.

## NOTES

- 1. Applicable fluids for standard construction: water(cold, hot or sea), weak acids, alkalies, compressed air etc.
- 2. Different elastomers are available for other fluids (e.g. oil). Contact factory for technical assistance.
- 3. Threading standard as per customer specifications (NPT, BSPT)
- 4. Expansion joints must be installed per FSA technical handbook guidelines and control units must installed if system pressure (test/surge/operating) exceeds 150psig to prevent voiding warranty.

## **FEATURES**

- \* Reduces noise and vibration transmission.
- \* Eliminates stress due to thermal expansion and piping misalignment.
- \* Double bellow design allows for greater axial, transverse, and angular movements.
- \* Precision molded of synthetic rubber.
- \* Synthetic fiber re-inforcement
- \* Corrosion resistant materials
- \* Easy field installation

## MATERIALS (see figure)

WATERIALS (See figure)							
No.	Part	Material					
1,2	Flanges	Cast SUS 201					
3,4	Nuts	Zinc plated carbon steel					
5	Tube + Cover	EPDM					
6	Threaded union	Cast SUS 201					
7	Bolts	Zinc plated carbon steel					
8	Reinforcing fabric	Polyester					

Notes / Remarks :	Project :	Title:	FCU-T	Drawing no.
	Client :		Rubber Expansion Joints	S-2500.06
	Consultant :		Twin Bellow, Screwed Connection	
	Representative :			Rev. <b>1</b>